



Number	65139/03	Replaces	65139/02
Issued	25-10-2016	Scope	KE 52
Contract number	Q 98/011	Page	1-3


Product Certificate

Valves

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

AVK International A/S

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 52, for "Valves for gas distribution systems with maximum operating pressure less than or equal to 16 bar." dated March 2015.



Bouke Meekma
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Product Certification.

This certificate consists of 3 pages.
Publication of the certificate is allowed.



Number	65139/03	Replaces	65139/02
Issued	25-10-2016	Scope	KE 52
Contract number	Q 98/011	Page	2-3

Valves

PRODUCT SPECIFICATION

Gate valves made of nodular cast iron (GGG 50).

AVK series 02/70

Flange connection DN 40, DN 50, DN 65, DN 80, DN 100, DN 125, DN 150, DN 200, DN 250, DN 300, DN 350, DN 400, DN 450, DN 500, DN 600.
Maximum operating pressure 16 bar.

AVK series 46/70 005

Spigot end for steel pipes DN 50, DN 65, DN 80, DN 100, DN 125, DN 150, DN 200, DN 250, DN 300 and DN 400.
Maximum operating pressure 16 bar.

AVK series 06/70

Flange connection DN 40, DN 50, DN 65, DN 80, DN 100, DN 125, DN 150, DN 200, DN 250, DN 300, DN 350, DN 400, DN 450, DN 500, DN 600.
Maximum operating pressure 16 bar.

AVK series 36/90 170

PE 100 spigot ends DN 65, DN 80, DN 100, DN 125, DN 150, DN 200, DN 250, DN 300 and DN 400.
Maximum operation pressure 10 bar.

AVK series 36/90 171

PE 100, SDR 11 spigot ends DN 65, DN 80, DN 100, DN 125, DN 150, DN 200, DN 250 and DN 300.
Maximum operation pressure 10 bar.

AVK series 36/90 185

PE 100, SDR 11 spigot ends DN 65, DN 80, DN 100, DN 125, DN 150, DN 200, DN 250, DN 300 and DN 400.
Maximum operation pressure 10 bar.

AVK series 36/9x 170

PE 100, SDR 11 spigot ends DN 25, DN 32, DN 40 and DN 50.
Maximum operation pressure 10 bar.

APPLICATION AND USE

Gas distribution valves with a maximum operating pressure less than or equal to 16 bar. The valves are for use in gas installations for 2nd family and 3rd family gases according to EN 437. The specific functional recommendations for application of these valves in gas supply systems are described in NEN 7244, NEN-EN 12007 and national and international norms and/or regulations.

Number	65139/03	Replaces	65139/02
Issued	25-10-2016	Scope	KE 52
Contract number	Q 98/011	Page	3-3

Valves

MARKING

- Manufacturer's name or trademark
- PN,
- Direction of flow (if necessary).
- Nominal size DN,
- Traceability identification,
- The GASTEC QA certification mark.

Place of the mark:

On the body of the valve in a clearly visible position.

Method of marking:

Non-erasable.

1. Check at the time of delivery whether:
 - 1.1 the producer has delivery in accordance with the agreement;
 - 1.2 the mark and the marking method are correct;
 - 1.3 the products show no visible defects as a result of transport etc.
 2. If you should reject a product on the basis of the above, please contact:
 - 2.1 AVK International A/S
and, if necessary,
 - 2.2 Kiwa Nederland B.V.
 3. Consult the producer's processing guidelines for the proper storage and transport methods.
 4. Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.
-